

Sampling Point: TP01

PWS ID: IL0970550

EEA Methods									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed Date	EEA ID #
335-67-1	Perfluorooctanoic acid (PFOA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
1763-23-1	Perfluorooctanesulfonic acid (PFOS) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
375-73-5	Perfluorobutanesulfonic acid (PFBS) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
375-85-9	Perfluoroheptanoic acid (PFHpA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
355-46-4	Perfluorohexanesulfonic acid (PFHxS) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
375-95-1	Perfluorononanoic acid (PFNA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
335-76-2	Perfluorodecanoic acid (PFDA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
307-24-4	Perfluorohexanoic acid (PFHxA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
307-55-1	Perfluorododecanoic acid (PFDoA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
72629-94-8	Perfluorotridecanoic acid (PFTrDA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
2058-94-8	Perfluoroundecanoic acid (PFUnA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
2991-50-6	N-ethyl Perfluorooctanesulfonamidoacetic acid \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
2355-31-9	N-methyl Perfluorooctanesulfonamidoacetic acid \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
13252-13-6	HFPO-DA/GenX \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
919005-14-4	ADONA \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
756426-58-1	9CI-PF3ONS/F-53B Major \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
763051-92-9	11CI-PF3OUdS/F-53B Minor \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906
376-06-7	Perfluorotetradecanoic acid (PFTeDA) \$	537.1	---	2.0	< 2.0	ng/L	01/21/21 08:12	01/22/21 10:27	4816906

\$ The state of origin does not offer certification for this parameter.

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Reg Limit Type:	MCL	SMCL	AL
Symbol:	*	A	I